

**ENLARGED HEPZIBAH PSD
POST OFFICE BOX 85, 18 SABLE CIRCLE
REYNOLDSVILLE, WV 26422
TELEPHONE - 304-623-2217
FAX – 304-626-3326**

ENLARGEDHEPZIBAH@ENLARGEDHEPZIBAHPSD.COM

**DARLENE SWIGER, CHAIRMAN
SHARON HAMILTON, TREASURER**

**FRED MARTIN, SECRETARY
KEVIN SHORT, GENERAL MANAGER**

GUIDELINES FOR CONNECTING YOUR WATER LINE

We recommend all lines be replaced back to the house with ¾" or 1" polyethylene class 200 (SDR 9) service tubing and an inline shut off valve installed at the house. The meter setters are not to be considered a shut off for your waterline. Customers are not permitted access to the meter pits. Only employees of Enlarged Hepzibah PSD are permitted access to the meter pits. If you choose to use your existing waterline, it will be required to pass a leak detection test. If the line does not pass a leak detection test, the line will have to be replaced or repaired at that time. Present sources of water will not be permitted to be connected to any waterlines served by the Enlarged Hepzibah PSD water system. Waterlines will be disconnected from your present water supply prior to connecting and switching to the Enlarged Hepzibah PSD water system and any present or future cross-connections shall be eliminated from your system.

We request that you call and make an appointment to have the water meter and pressure reducing valve (if required) installed. A cross-connection survey inspection will also be done at this time. After this is completed, the connection can be made at the household and/or meter.

A \$102.00 Water Security Deposit must be paid to Enlarged Hepzibah PSD before hook up is allowed.

CONTRACTOR HAS USED ¾" POLYETHYLENE CLASS 200 (SDR 9) AS A SERVICE LINE TO YOUR PROPERTY.

ITEMS REQUIRED:

1. Leak Detection – waterline required to pass leak detection test
2. Cross-Connections – disconnect any present water source from lines being served by Enlarged Hepzibah PSD waterlines.

ITEMS RECOMMENDED:

1. Shut off Valve – to be installed on customer's side of service line.
2. ¾" or 1" polyethylene class 200 (SDR 9) service tubing.
3. Pipe needs to be buried a minimum of two (2) feet: we recommend three (3) feet.
4. All existing waterlines, hot water tanks and faucet screens in your home should be flushed thoroughly after connection to the Enlarged Hepzibah PSD water supply.

NOTE: If you are renting, please call Enlarged Hepzibah PSD Monday – Friday 7:00 AM – 3:30 PM at 304-623-2217 to advise us and please submit these instructions to your landlord.

**ENLARGED HEPZIBAH PSD
POST OFFICE BOX 85, 18 SABLE CIRCLE
REYNOLDSVILLE, WV 26422
TELEPHONE - 304-623-2217
FAX – 304-626-3326**

ENLARGEDHEPZIBAH@ENLARGEDHEPZIBAHPSD.COM

DARLENE SWIGER, CHAIRMAN
SHARON HAMILTON, TREASURER

FRED MARTIN, SECRETARY
KEVIN SHORT, GENERAL MANAGER

GUIDELINES FOR CONNECTING YOUR SEWER LINES

We recommend all lines be replaced back to the house with SDR 35 or Schedule 40 pipe. However, if you choose to use your existing sewer line it will be required to pass a Smoke Test and or Dye Test at a later date. If the line does not pass the Smoke Test and or Dye Test, the line will have to be replaced or repaired at that time.

Only water that goes through the water meter can be connected to the **SEWER LINE**.

Footage drains and down spouts are **NOT PERMITTED** to be connected into the sewer line.

PIPE SPECIFICATIONS:

- A. SDR 35 PVC with rubber o-ring gasket
- B. Schedule 40 PVC solvent weld (glue) joints
If using Schedule 40, remove plug and o-ring coupling and use Fernco Adapter.
- C. Other materials will be approved on a case-by-case basis.

ITEMS REQUIRED:

LINE INSPECTION: All lines must be inspected by an Enlarged Hepzibah PSD employee prior to covering pipe. Call the office at least three (3) days in advance at 304-623-2217 from 7:00 AM to 3:30 PM Monday through Friday to schedule an inspection.

A \$85.00 Sewer Security Deposit must be paid to Enlarged Hepzibah PSD before hook up is allowed.

ITEMS RECOMMENDED

- 1. A clean-out is recommended near the house for your convenience.
 - a. Traps recommended on all household drain line connections.
- 2. Pipe needs to be buried a minimum of two (2) feet.
 - a. Minimum slope ¼" per foot (2%) for 4" pipe.
 - b. Minimum slope 1/8" per foot (1%) for 6" pipe.

NOTE: If you are renting, please call Enlarged Hepzibah PSD Monday – Friday 7:00 AM – 3:30 PM at 304-623-2217 to advise us and please submit these instructions to your landlord.

ADDITIONAL INFORMATION: Pursuant to WV Legislative Rule 64CSR-9 Section 5.6A, property owners once connected to public sewer system are required for safety purposes to (1) remove old septic tank, or (2) have tank pumped out and then filled with insert material (i.e., dirt, gravel, rock sand, etc.).